

CERTIFICATE OF COMPLIANCE

Certificate Number E37780
Report Reference E37780-20200330
Issue Date 2020-APRIL-06

Issued to: Peter Paul Electronics Co Inc
480 John Downey Dr
PO BOX 1180
New Britain CT 06051-2910

This certificate confirms that representative samples of SOLENOIDS FOR USE IN HAZARDOUS LOCATIONS
See Addendum Page for Models


Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: See Addendum Page for Standards
Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E37780
Report Reference E37780-20200330
Issue Date 2020-APRIL-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.


Solenoids for use in hazardous locations, Class I, Groups C and D; Class I, Div. 2; Groups A, B, C and D; and Class II, Groups E, F, and G.

Models OEL21, OEL22, OEL23, OEL24, OEL25 or OEL26, followed by any single letter A through Z, followed by any single letter A through Z, followed by D, followed by D, U, Z, or X, may be followed by B, followed by C, CC, E, or EC, followed by P or F, followed by 12 or 24. May be prefixed by V or VO.

Models OEL21, OEL22, OEL23, OEL24, OEL25 or OEL26, followed by Z, followed by any four numbers, followed by any single letter A through Z, may be followed by B, followed by C, CC, E, or EC, followed by P or F, may be followed by additional letters A through Z. May be prefixed by V or VO.

Standards for Safety:

UL 429 & CAN/CSA C22.2 No. 139-1982, Electrically Operated Valves;
UL 1203 Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations;
UL 121201 & CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations;
CSA C22.2 No. 30-M1986, Explosion-Proof Enclosures for Use in Class I Hazardous Locations;
CSA C22.2 No. 25-17, Enclosures for Use in Class II, Division 1, Groups E, F, and G Hazardous Locations



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

